



CENERGIE  
INTEGRAAL DUURZAAM





# Pilot Port of Antwerp

## Batteries for Kieldrechtlock

Toon Possemiers  
CEO



# Partners: PoA, A sustainable Port



Translate the lowering of Belgian carbon emissions into 3 strategic projects

- Initiate the transition towards a **carbonless and circular economy in port area**.
- Walk the talk by **sustainably investing in existing and future maritime base infra- and superstructure**.
- **Integrate a digital ecosystem** within our port that can support transversal supply chains.

# Partners: PoA, A sustainable Port

## Recent initiatives

- Multi fuel port
- Hydro tug: the world's first hydrogen operated tug
- Ecluse: a steam network with residual heat
- Shore-side power



## Partners: Vlaams Energie Bedrijf

*"Wij ontzorgen de publieke sector naar een duurzamer en efficiënter energiebeheer en ondersteunen in het bereiken van de klimaatdoelstellingen."*

Strategic program sustainability  
2017: batterytechnology

Expansion of RE mix  
PV

Feasibility study stationary batteries


Study for potential cases

Synergy batteries – sun  
R1

Ext companies: Mismatch use and surface  
PoA: Few potential sites, only locks

Pilot Kieldrechtsluis

# Applications





Sint-Gillis-Waas

Zillebeek

Zwiindrecht

Antwerpen

Melseledijk


Vliegenstal

Museum aan de Stroom  
Scheide

N49a


N70

N




# Kieldrechtlock

- + 1,2 GWh yearly
- Variable consumption pattern
- 24/7



7 days consumption pattern KIS (kW)





# Business cases

- Peak shaving
- *Buffering of renewable energy ➔ 500 – 1.500 kWh storage*
- Back-up power



# Case buffering 1400 kWh - 800 kWp

- C-rate = 0,25
- SoC = 15-100%




# Case buffering 1400 kWh - 800 kWp

- *Self consumption 80% i.o.50%*
- 45% of consumption covered by PV (i.o. 28%)
- 243 MWh stored



# Case buffering 1400 kWh - 800 kWp



Buffering alone will not be feasible. Need for extra income.

# Balancing markets

## Risk of imbalances

- Balancing Service Providers:
  - Offer capacity
  - Decrease consumption
  - Increase consumption
- Automatic or controlled and proportional reaction
- Possible income

Situation at 15/10/2020 from 10:02 to 11:00


Quarter	Minute	Quality status	NRV (MW)	SI (MW)	a (€/MWh)	MIP (€/MWh)	MDP (€/MWh)	SR (€/MWh)	SI < - I C (MW)	Price (€/MWh)
11:00 > 11:15	11:00	Non-validated	-204,131	315,503	2,21	0,00	<b>11,01</b>			8,8
10:45 > 11:00	10:59	Non-validated	-193,152	217,751	3,21	59,00	<b>11,01</b>			7,8
10:45 > 11:00	10:58	Non-validated	-194,998	216,737	3,18	59,00	<b>11,01</b>			7,8
10:45 > 11:00	10:57	Non-validated	-198,225	217,671	3,20	59,00	<b>11,01</b>			7,8
10:45 > 11:00	10:56	Non-validated	-203,650	219,216	3,24	59,00	<b>11,01</b>			7,7
10:45 > 11:00	10:55	Non-validated	-212,447	221,198	3,29	59,00	<b>11,01</b>			7,7
10:45 > 11:00	10:54	Non-validated	-222,801	227,546	3,45	59,00	<b>11,01</b>			7,5
10:45 > 11:00	10:53	Non-validated	-232,451	238,772	3,76	59,00	<b>11,01</b>			7,2
10:45 > 11:00	10:52	Non-validated	-241,047	251,550	4,14	59,00	<b>11,01</b>			6,8
10:45 > 11:00	10:51	Non-validated	-248,225	265,177	4,58	59,00	<b>11,01</b>			6,4
10:45 > 11:00	10:50	Non-validated	-253,615	265,934	4,61	0,00	<b>11,01</b>			6,4
10:45 > 11:00	10:49	Non-validated	-259,725	281,167	5,17	0,00	<b>11,01</b>			5,8

# Demand site management

- Frequency Containment Reserves R1
  - Automatic reaction within 30 seconds
- Frequency restoration reserve R2
  - Controlled by Elia
  - Activated within 7,5 min
- Replacement reserve R3
  - Controlled manually
  - Activated within 15 min

# Potential impact of R1

- C-rate = 0,85
- 80% battey capacity
- 25% power available for buffer
- 75% power available for R1







11% of total energy necessary to deliver R1 services downwards for 10 minutes at full capacity with 75% of battery power capacity of a 0.85c battery

58-63% of total energy available for buffering and 25% of power capacity can be used to optimize in this range. This 25% is also used to keep the battery in the correct range for R1


11% of total energy necessary to deliver R1 services upwards for 10 minutes with at full capacity with 75% of battery power capacity of a 0.85c battery

15-20 % of battery capacity reserved to avoid deep cycles and guarantee live span

Simulation without R1:

Simulation with R1:


## IRR in functie van batterijgrootte voor # PV installaties

- Life span ⇔ full cycles
- 72% buffering (i.o. 80%)
- Need for aggregator



Direct consumption of solar PV:

Battery size kWh	PV size (kWp)									
	100	200	300	400	500	600	700	800	900	1000
0	99,97	95,07	84,97	74,65	66,29	59,62	54,20	49,71	45,91	42,65
200	100,00	99,16	91,50	81,07	72,14	64,91	59,03	54,12	49,99	46,45
400	100,00	99,94	95,40	85,75	76,80	69,23	63,02	57,82	53,45	49,73
600	100,00	99,99	97,65	89,34	80,64	73,02	66,56	61,14	56,57	52,68
800	100,00	99,99	98,88	92,16	83,90	76,37	69,82	64,22	59,47	55,43
1000	100,00	100,00	99,43	94,31	80,64	79,33	72,77	67,10	62,19	58,00
1200	100,00	100,00	99,69	95,92	81,97	81,92	75,47	69,79	64,79	60,44
1400	100,00	100,00	99,82	97,11	90,95	84,21	77,02	72,24	67,22	62,76
1600	100,00	100,00	99,89	98,02	92,64	86,21	80,11	74,47	69,46	64,97
1800	100,00	100,00	99,91	98,60	93,97	87,91	81,98	76,45	71,45	66,94
2000	100,00	100,00	99,94	98,90	94,93	89,27	83,49	78,07	73,09	68,60

IRR 15 jaar (%):

	100	200	300	400	500	600	700	800	900	1000
	0	5,26	7,55	7,31	6,76	6,27	5,87	5,58	4,60	4,67
200	4,76	6,81	7,10	6,84	6,49	6,18	5,92	5,07	5,12	5,13
400	4,56	6,23	6,80	6,76	6,55	6,31	6,10	5,35	5,40	5,41
600	4,45	5,84	6,50	6,63	6,53	6,37	6,21	5,55	5,59	5,61
800	4,38	5,57	6,24	6,49	6,48	6,38	6,27	5,68	5,73	5,75
1000	4,33	5,37	6,01	6,34	6,41	6,37	6,29	5,78	5,83	5,86
1200	4,30	5,21	5,82	6,20	6,37	6,34	6,30	5,85	5,91	5,94
1400	4,27	5,09	5,66	6,07	6,24	6,29	6,19	5,89	5,96	6,00
1600	4,25	5,00	5,52	5,95	6,16	6,24	6,27	5,92	6,00	6,04
1800	4,23	4,92	5,41	5,83	6,07	6,18	6,23	5,92	6,01	6,07
2000	4,22	4,85	5,31	5,72	5,98	6,11	6,18	5,91	6,01	6,07

Self reliance (% of consumption self-produced):

	100	200	300	400	500	600	700	800	900	1000
	0	7,02	13,35	17,90	20,97	23,28	25,12	26,64	27,93	29,01
200	7,02	13,93	19,28	22,77	25,33	27,35	29,02	30,40	31,59	32,62
400	7,02	14,04	20,10	24,09	26,96	29,17	30,98	32,48	33,78	34,92
600	7,02	14,04	20,57	25,09	28,31	30,76	32,72	34,35	35,75	37,00
800	7,02	14,04	20,83	25,88	28,46	32,18	34,32	36,07	37,59	38,92
1000	7,02	14,04	20,95	26,49	30,42	33,42	35,77	37,69	39,30	40,72
1200	7,02	14,04	21,00	26,94	31,21	34,52	37,10	39,20	40,94	42,44
1400	7,02	14,04	21,03	27,28	31,94	35,48	38,00	40,58	42,48	44,07
1600	7,02	14,04	21,04	27,53	32,53	36,31	39,38	41,83	43,90	45,62
1800	7,02	14,04	21,05	27,70	32,99	37,04	40,29	42,95	45,15	47,00
2000	7,02	14,04	21,05	27,78	33,33	37,61	41,04	43,85	46,19	48,17









[WWW.CENERGIE.BE](http://WWW.CENERGIE.BE)

# Outdoor energy system

- Batteries
- Convertor
- BMS
- Cooling
  - Liquid cooled battery module
  - Liquid cooled rack







# Grid connection

High Voltage ⇔ Low Voltage

- High Voltage
  - Investment in equipment
- Low Voltage
  - Investment in cabling + converter

4 motors of the lock and 2 of the bridges on LV

No space in HV cabine

➔ Low voltage

## Lessons learned

- PV = easy
- Batteries = easy
- Combination of PV, batteries and consumer ≠ easy



**CENERGIE**  
INTEGRAAL DUURZAAM

Dank u voor uw aandacht.